

Doc. No. 1071-v1 DRAFT 6

Date: 07/16/2012

Page 1 of 4



Fermilab

# Functional Requirements Specification Bunching cavity for PXIE MEBT

Prepared by:	Fermilab	Extension
T. Khabiboulline, RF Engineer	TD/SRF	X4693
Approved by:	Fermilab	Extension
I. Terechkine, Lead Engineer	TD/SRF	X4017
Approved by:	Fermilab	Extension
V. Yakovlev, SRF department head	TD/SRF	X3888
Approved by:	Fermilab	Extension
A. Shemyakin, MEBT Lead Scientist	AD/Project X	X4440
Approved by:	Fermilab	Extension
V. Lebedev, CW Linac Scientist	AD/Project X	X2258
Approved by:	Fermilab	Extension
R. Stanek, PXIE Lead Engineer	Directorate	X3519



Doc. No. 1071-v1 DRAFT 6

Date: 07/16/2012

**Page** 2 **of** 4

#### **Revision History**

Revision	Date	Section	Revision Description
		No.	
1.0	03/05/2012	All	Initial Draft
1.1	03/08/2012	All	Draft
1.2	03/13/2012	All	Draft
1.3	05/31/2012	All	Draft
1.4	06/14/2012	All	Draft
1.5	06/21/2012	All	Draft
1.6	07/16/2012	All	Draft



Doc. No. 1071-v1 DRAFT 6

Date: 07/16/2012

**Page** 3 **of** 4

#### Introduction and scope

Project X is a high intensity proton facility conceived to support a world-leading physics program at Fermilab [1]. The Project X Injector Experiment (PXIE) will be an integrated systems test [2] that will validate the concept for the Project X front end.

The Medium Energy (2.1 MeV,  $\beta$  = 0.067) Beam Transport (MEBT) section [3] includes three Bunching cavities operating at 162.5 MHz. This document specifies design cavity parameters that are essential for the beam dynamics, cavity performance, and cavities integration into MEBT.

#### **Functional Requirements**

The cavities and couplers will be designed to operate with a maximum forward power under any reflection condition.

The tuners have to be capable of supporting reliable cavity operation with 10 mA beam.

General			
	Minimum beam aperture (ID), mm		
	Overall module length; flange-to-flange, m		
	Positioning accuracy relative to the projected beam trajectory:		
	X, Y, Z, RMS, mm	0.5	
	Pitch and Yaw, RMS, mrad	3	
	Nominal cavity operational vacuum with beam, Torr	3e-8	
Cavity			
	Frequency, MHz	162.5	
	Operating mode		
	Operating temperature, °C		
	Nominal accelerating voltage at beta=0.067, MV		
	Maximum accelerating voltage at beta=0.067, MV		
	Power loss at maximum voltage, kW		
	Frequency tuning range, kHz		
	Maximum water supply pressure, Bar	20	
Coupler			
	Coupler Power Rating (full reflection), kW	4	
	Coupling coefficient	1.0	
	Coupler feeder – standard coaxial with impedance, Ohm	50	



Doc. No. 1071-v1 DRAFT 6

Date: 07/16/2012

Page 4 of 4

#### Instrumentation

Each cavity must have a provision for use of the next instrumentation:

- Cavity field probe.
- RF coupler e-probe.
- Cavity vacuum monitor

#### **Engineering and Safety Standards**

All vacuum vessels, pressure vessels, and piping systems will be designed, documented, and tested in accordance with the appropriate Fermilab ES&H Manual (FESHM) chapters. Bellows shall be designed using the requirements of the Expansion Joint Manufacturers Association (EJMA).

#### **Quality assurance**

A Bunching cavity traveler is to be developed documenting all stages of inspection and test.

#### References

Documents with reference numbers listed are in the Project X DocDB: <a href="http://projectx-docdb.fnal.gov">http://projectx-docdb.fnal.gov</a>

[1] Project X Functional Requirements Specification

Document #: Project-X-doc-658

[2] Project X Injector Experiment Functional Requirements Specification

Document #: Project-X-doc- 980

[3] PXIE MEBT Functional Requirements Specification

Document #: Project-X-doc-938